





Test Certificate

Date issued 17-02-2022 Report number 4403-2

Certificate number ErP/ELEC/0558/22/002 Original/Amendment Original

EC Ecodesign Certificate

Issued by Kiwa Ltd

Circulating Pump Model Name	Energy Efficiency Index, ε _{ΕΕΙ}	Test Report
Tucson OBCP 25/6/130	0.21	4403-2

Manufacturer's Name and Address:

Tucson Pumps Ltd Instantor Works Santry Avenue Dublin D09 K160 Ireland

Declaration

Kiwa Limited declares that Energy Efficiency Index test results for the products listed above have been obtained in accordance with the requirements of the Energy Using Products Directive according to Commission Regulation (EC) No 641/2009 (Directive 2005/32/EC) using the relevant methods of measurement and calculation of energy efficiency index for glandless circulators as detailed in 2013/C 254/04 of the Official Journal of the European Union (OJEC) C254 dated 4 September 2013.

Signed on behalf of Kiwa Limited

Mr A J Pittaway – Certification Officer

Kiwa Gastec

Kiwa House

Malvern View Business Park

Stella Way

Bishops Cleeve

Cheltenham

GL52 7DQ

United Kingdom

T +44 (0)1242 677877

F +44 (0)1242 676506

www.kiwa.co.uk

This certificate consists of 1 page. Publication of this certificate is permitted.