



EC Ecodesign Certificate

Issued by Kiwa Limited

Certificate Number: ErP/ELEC/0558/21/002 Copy Number: 01

Issue Date: 11 Feb 2021

Test Fuel	Model Name	Circulating Pump	Test Report
		Energy Efficiency Index, ϵ_{EEI}	
Electric	Tucson Type RS25/5EAQ	0.20	4397-1
Electric	Tucson Type RS25/6EAQ	0.20	4397-2

Manufacturer's Name and Address:

Tucson Pumps Ltd
Instantor Works
Santry Avenue
Dublin D09 K160
Ireland

Declaration

Kiwa Limited declares that Energy Efficiency Index test results for the products listed above have been obtained in accordance with the requirements of the Energy Using Products Directive according to Commission Regulation (EC) No 641/2009 (Directive 2005/32/EC) using the relevant methods of measurement and calculation of energy efficiency index for glandless circulators as detailed in 2013/C 254/04 of the Official Journal of the European Union (OJEC) C254 dated 4 September 2013.

Signed on behalf of Kiwa Limited

Mr A J Pittaway – Certification Officer